



REF. TO: STANDARD TANK  
DATE: 05/20/08

DWG BY: AH

TITLE:

**AHDW-3000-7P**

SCALE: 1:40

DESCRIPTION:

ABOVE GROUND, DOUBLE WALL  
7 GA. INNER/10 GA. OUTER  
STEEL STORAGE TANK  
2938 GALLONS

FINISH:  
SURFACE PREP: SPCC SP-3; ONE  
SPRAY COAT OF PRIMER; OPT FINISH  
APPROX. WEIGHT: 5157 lbs ± 5%

CAPACITY:

LEGEND: ID - (QTY. OF OPENINGS) PART  
A - (3) 2" NPT CPL D - (1) 4" NPT CPL  
B - (1) 8" INNER EVENT CPL E - (1) 2" INSPECTION PIPE  
C - (1) 8" OUTER EVENT FLANGE F - (2) FORGED LIFT LUG



Underwriters  
Laboratories Inc.  
LISTED



1500 HWY 117 S.  
GOLDSBORO, NC 27530  
P: (919) 734-8328  
F: (919) 736-4550

SIGNED APPROVAL: