



REF. TO: STANDARD TANK
DATE: 04/24/09

DWG BY: JR

TITLE: **AHDW-4000/64-7P**

SCALE: 1:48

LEGEND: ID - (QTY. OF OPENINGS) PART

- A - (4) 2" NPT CPL
- B - (1) 8" INNER EVENT CPL
- C - (1) 8" OUTER EVENT FLANGE
- D - (1) 4" NPT CPL
- E - (1) 2" INSPECTION PIPE
- F - (2) FORGED LIFT LUG

DESCRIPTION:

ABOVE GROUND, DOUBLE WALL
7 GA. INNER/10 GA. OUTER
STEEL STORAGE TANK
3917 GALLONS

FINISH:
SURFACE PREP: SPCC SP-3; ONE
SPRAY COAT OF PRIMER; DPT FINISH
APPROX. WEIGHT: 6638 lbs ± 5%

CAPACITY:

1500 HWY 117 S.
GOLDSBORO, NC 27530
P: (919) 734-8328
F: (919) 736-4550

SIGNED APPROVAL:



Underwriters
Laboratories Inc.
LISTED

