



REF. TO: STANDARD TANK  
DATE: 05/20/08

DWG BY: AH

TITLE:

**AHDW-525-12P**

SCALE: 1:20



LEGEND: ID - (QTY. OF OPENINGS) PART  
 A - (4) 2" NPT CPL D - (1) 2" INSPECTION PIPE  
 B - (1) 4" INNER EVENT CPL E - (1) FORGED LIFT LUG  
 C - (1) 4" OUTER EVENT FLANGE

DESCRIPTION: ABOVE GROUND, DOUBLE WALL  
 12 GA. INNER/12 GA. OUTER  
 STEEL STORAGE TANK  
 CAPACITY: 508 GALLONS

FINISH: SURFACE PREP. SPCC SP-3; ONE  
 SPRAY COAT OF PRIMER; DPT FINISH  
 APPROX. WEIGHT: 890 lbs ± 5%

**TURNER TANKS**  
 1500 HWY 117 S.  
 GOLDSBORO, NC 27530  
 P: (919) 734-8328  
 F: (919) 736-4550

SIGNED APPROVAL: