



DESCRIPTION:	ABOVE GROUND DOUBLE WALL STEEL STORAGE TANK, 525 GALLONS	REF. TO:	
MATERIAL:	1/2 GA. INNER/1/2 GA. OUTER	DATE:	
CONSTRUCTION:	WELDED USING UL-142 STANDARDS	TITLE:	ASDW-525-12P
OPENINGS:	4-2" CPL'S 1-4" INNER EVENT CPL 1-4" OUTER EVENT FLANGE	SIZE LEGEND:	A - 2" CPL B - 4" INNER EVENT CPL C - 4" OUTER EVENT FLANGE D - 2" INSPECTION PIPE E - FORCED LIFT LUG
FINISH:	SURFACE PREP: SPEC SP-3 ONE SPRAY COAT OF RED PRIMER	TURNER TANKS: GOLDSBORO, NC (919) 734 - 8328	SCALE: 1:20
		APPROVAL:	