



REF. TO: STANDARD TANK
 DATE: 07/31/09
 DWG BY: JR

TITLE: **LBDW-165-12P**
 SCALE: 1:20

LEGEND: ID - (QTY. OF OPENINGS) PART

- A - (5) 2' FNPT FLANGE D - (1) RMP
- B - (1) 3' INNER EVENT FLANGE
- C - (1) 3' OUTER EVENT FLANGE

DESCRIPTION: ABOVE GROUND, DOUBLE WALL 12 GA. INNER/12 GA. OUTER STEEL, BENCH STORAGE TANK 170 GALLONS

FINISH: SURFACE PREP, SPCC SP-3; ONE SPRAY COAT OF PRIMER; DPT FINISH APPROX. WEIGHT: 385 lbs ± 5%

SIGNED APPROVAL:



1500 HWY 117 S.
 GOLDSBORO, NC 27530
 P: (919) 734 - 8328
 F: (919) 736 - 4550